

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7270-1521:103 Page 1 of 1

**CATEGORY:** Heat Detector

**LISTEE:** Siemens Building Technologies, Inc., 1000 Deerfield Parkway, Buffalo Grove, IL 60089  
Contact: Albert Badalpour (847) 215-1050

**DESIGN:** Model SIGA-HFS, SIGA-HFS-LG, SIGA-HRS and SIGA-HRS-LG heat detectors. Model SIGA-HFS, HFS-LG are 135NF fixed temperature detector and Model SIGA-HRS, -HRS-LG are 135NF fixed temperature and a 15NF/min rate of rise detector. Refer to listee's data sheet for additional detailed model descriptions and operational considerations.

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Model number, electrical rating, UL label.

**APPROVAL:** Listed as heat detector for use with listee's separately listed compatible bases (CSFM Listing No. 7300-1388:170) and fire alarm control units.

**NOTE:** Formerly 7270-1469:103

**XLF:** 7270-1388:185

12-21-98



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

**JUNE 18, 2002**

*Listing Expires **June 30, 2003***

Authorized By:

**DIANE K. AREND**, Senior Deputy  
Program Manager